



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NV-5180AO0703

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Distributor <i>Vertreiber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Product Category <i>Produktart</i>	Greasing and sealing materials: Protection tape against corrosion (5180)
Product description <i>Produktbezeichnung</i>	Corrosion prevention tape based on petrolatum
Model <i>Modell</i>	DENSO®-Plast
Test reports <i>Prüfberichte</i>	Laboratory control test: 21-01256-KP03 from 21.06.2023 (EBI) Type testing: 23/107/5180/1 from 09.12.2013 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN 30672-1 (01.05.2019) DIN EN 12068 (01.03.1999)

Date of Expiry / File No. 31.08.2028 / 23-0449-GNV
Ablaufdatum / Aktenzeichen

16.12.2024 Cat A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
DENSO®-Plast	Stress class: A Permanent operating temperature: up to +30 °C Designation according to standard: Coating EN 12068-A 30 respectively DIN 30672-A 30	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Application with 66 % overlap (3 layers) to applied cold

DVCE