



DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NV-5181DM0054

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Distributor <i>Vertreiber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Product Category <i>Produktart</i>	Greasing and sealing materials: Coatings for steel tubes (5181)
Product description <i>Produktbezeichnung</i>	single tape corrosion prevention coating with primer
Model <i>Modell</i>	DENSOLEN®-AS40 HT mit DENSOLEN®-HT100 Primer
Test reports <i>Prüfberichte</i>	Type testing: 20-00247 from 15.02.2021 (EBI) Laboratory control test: 20-00247-KP04 from 09.04.2025 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN EN ISO 21809-3 (01.09.2020)

Date of Expiry / File No. 15.02.2031 / 25-0677-GNV
Ablaufdatum / Aktenzeichen

70028-04-A-DE

24.11.2025 Fi A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvgw-cert.com
www.dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
DENSOLEN®-AS40 HT mit DENSOLEN®-HT100 Primer	Permanent operating temperature: ...+100 °C Designation according to standard: coating DIN EN ISO 21809-3 Type: 12A-3	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

application: cold handle protection tape against corrosion with 2 layers on primer

DVGW
CERT