



DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NV-5180AL0257

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Distributor <i>Vertreiber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Product Category <i>Produktart</i>	Greasing and sealing materials: Protection tape against corrosion (5180)
Product description <i>Produktbezeichnung</i>	Two tape corrosion prevention coating with primer
Model <i>Modell</i>	DENSOLEN®-N15/-PE5
Test reports <i>Prüfberichte</i>	Type testing: 15/002/5180/4 from 15.07.2015 (EBI) Laboratory control test: 21-01255-KP05- from 03.07.2025 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN EN 12068 (01.03.1999) DIN 30672-1 (01.05.2019)

Date of Expiry / File No. 31.08.2030 / 25-0282-GNV
Ablaufdatum / Aktenzeichen

70028-04-A-DE

15.08.2025 Cat A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

15.08.2025



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dv-gw-cert.com
www.dv-gw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
DENSOLEN®-N15/-PE5	Stress class: C Permanent operating temperature: +30 °C Designation according to standard: Coating EN 12068-C 30 resp. DIN 30672-1-C 30	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

handling: cold handle protection tape against corrosion with 2 inside- and 2 outside layers.

